## **DECLARATION OF PERFORMANCE**



According to Annex III of the Regulation (EU) Nr.305/2011 (Construction Products Regulation) fischer FFC® FireStop Collar

Collar

1121 - CPR - JA5094

ETA 15-0696 1121-CPR-JA5094

EN

1. Unique identification code of product-type: FFC FireStop Collar

2. Type, Batch or serial number as required pursuant to Article 11(4): See ETA 15/0696: See batch number displayed on product.

3. Intended use or uses of construction product, in accordance with the applicable harmonized technical specification: Fire Stopping and Sealing Products for Penetration Seals, See ETA 15/0696

Pipe Penetration	Non insulated combustible pipes	The field of application has to comply with the content of ETA 15/0696

- 4. Name, registered trade name or registered trade mark and contact address as required pursuant to article 11(5): fischerwerke GmbH & Co. KG, Klaus-Fischer-Str. 1, 72178 Waldachtal, DEUTSCHLAND
- Authorized representative: N/A
- 6. System or systems of assessment and verification of performance of the construction product as set out in Annex V: AVCP System 1
- 7. Harmonized standard: N/A
- 8. In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued: Warrington Certification Limited issued European Technical Approval ETA 15/0696 on the basis of ETAG 026 part 1 General June 2013 fire protection products & ETAG 026 part 2 August 2011 fire stopping and fire sealing products & issued certificate of conformity 1121-CPR-JA5094
- 9. Declared performance:

Essential Characteristics	Performance/Harmonised technical specification
Reaction to Fire	Class E According to EN13501-1
Resistance to Fire	Resistance to fire performance & field of application in accordance with EN13051-2 See ETA 15/0696 Annex A
Dangerous Substance	See ETA 15/0696 Clause 1.5
Service & Durability	Type X Intended for use in conditions exposed to weathering in accordance with EOTA technical documents TR024
Other	Not applicable/No performance determined

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 6. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:

Dave Hanrahan

Product Manager FireStop ST-F

1.V. Junta

Güral Savim

Head of SaMontec - Installation Systems ST-S

i.V. G. Seri

