

	Page	Tested To							Approved To				Application								
		BS 476: Part 20	BS EN 1366-3	BS EN 1366-4	DIN 4102	AS 1530	ASTM E814 (UL 1479)	ASTM E 1966 (UL 2079)	ASTM E84 (UL 723)	ETA/CE MARK	UL Approved	Certifire Approved	FM Approval	Construction Joint	Perimeter Joints	Metallic Pipes	Insulated Pipes	Non-Metallic Pipes	Cable and Cable Trays	Air Ducts	Insulated Air ducts
FiAM Intumescent Acoustic Mastic	14	•	•	•				•	•	•	•	•	•	•	•			•	•		
FFRS Fire Rated Silicone Sealant	16	•		•					•		•		•								
RFS 640 Rapid Fire Seal	18	•					•	•	•	•		•	•	•	•				•	•	
FBB - ES Elastoseal	20	•		•					•				•	•							
UFS 310 Universal Fire- Stopping Sealant	22	•					•	•	•	•		•	•	•	•	•	•	•	•	•	•
FiGM Intumescent Graphite Mastic	24	•	•	•					•		•		•		•	•	•	•	•	•	
FBB Firestop Block	26	•	•		•										•				•		
FBS Foam Barrier System	28	•	•		•										•				•		
FiPW Intumescent Pipe Wrap	30	•	•						•		•						•	•			
FiWS Intumescent Wrap Strip	32						•	•		•		•					•	•	•		
FFC Firestop Collar	34	•	•						•								•	•			
FCID Cast In Device	36	•				•												•			
FiP Intumescent Pillow	38	•	•						•		•				•				•	•	
FiPP Putty Pads	40	•	•																•		
FCPS Coated Panel System	42	•	•						•		•				•	•	•	•	•	•	
FFSC Firestop Compound	44	•	•			•	•		•	•					•	•	•	•	•	•	
Fire   Barr FBB-VS/FM	46	•		•										•	•						
Firestop Foam	48	•		•	•									•							
Thermal Defense Wrap	50	•	•						•						•	•		•	•	•	